



ADDENDUM # 01

DATED: 12/07/2023

B39645

Fairfax Tower Signage Landscaping & Maintenance

The Purchasing Division must inform you of the following:

1. The Fairfax Trafficway tower location is it an 8-ft radius or 8-ft diameter? Please clarify. **It is an 8-ft radius circle around the tower.**
2. The 7th Street approx. 20' X 15' is one diameter and one the length of the edging, please clarify. **That location is on a corner. The 20' dimension is the curved length along the curb at the street. The 15' dimension is the depth of the area back to the parking lot/dead-end street.**
3. Buckskin edge color beige buckskin a natural stone? 4inch by 4inch random length? Above or below the 2-3 depth of stone and grass surface? **Yes, it is a natural stone with a random 4inch by 4inch length. Edging should be a single layer and sit above the depth of the river rock.**
4. River rock stone above or below the sign footing? **Even with the cement footing.**
5. Will application of chemical require a state pesticide license? **Yes, the state of Kansas requires all pest control technicians to be licensed to use pesticides on residential and commercial properties.**

Please sign and date this amendment and return it, along with your Bid.

NAME/BUSINESS: _____

ADDRESS: _____

MAILING ADDRESS: _____

CITY: _____, STATE: _____, ZIP CODE: _____

PHONE: (_____) _____ EMAIL.: _____

ATTENTION OF: _____

TITLE: _____

SIGNED: _____

DATE: _____

All questions should be directed to the Purchasing Department at (913)573-5440.